

RAINWATER TANKS

This is a **GUIDE ONLY** for minimum requirements for water tank sizes.

Refer to any Planning approval for the subject lot (if applicable) for relevant tank capacity.

On Demand (full town pressure)

- No tank required unless specified on a building approval

Mixed Demand (trickle feed) - combination of town and rain water

- Beaudesert/Tamborine area - 31,500 litre
 - Riemore Downs - 63,000 litre or 31,500 litre
 - Some properties in Country Club Estate require 45,000 litre
- Boonah area - 20,000 litre
- Ipswich area - no mixed demand

Tank Only (solely rain water)

- Beaudesert/Tamborine area - 45,000 litre
- Boonah area - 20,000 litre
- Ipswich area - 18,200 litre
- Or as specified in a Development Approval