

RAINWATER TANKS

This is a **GUIDE ONLY** for minimum requirements for water tank sizes when submitting new building applications.

Refer to any Planning approval for the subject lot (if applicable) for relevant tank capacity.

On Demand (full town pressure)

- No tank required unless specified on a building approval

Mixed Demand (trickle feed) - combination of town and rain water

- Beaudesert - 45,000 litre
 - Riemore Downs - 63,000 litre
- Boonah area - 20,000 litre
- Ipswich area - no mixed demand
- Or as specified in a Development Approval

Tank Only (solely rain water)

- Beaudesert/Tamborine area - 45,000 litre
- Boonah area - 20,000 litre
- Ipswich area - 18,200 litre
- Or as specified in a Development Approval

Canungra Rise Estate

- New dwellings with lots greater than 1,000m² - 31,500 litres
- New dwellings with lot less than 1,000m² - 5,000 litres

Replacement of Existing Water Tanks

If there is a requirement to replace any existing water tanks this can be done by replacing the old with new (same size) or larger. Please note a licenced plumber is required for the disconnection and connection to the new tank and that an application for building work may be applicable. Contact Council for further details if required.